

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-0067:221 Page 1 of 1

CATEGORY: Power Units

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Model PAD-3 notification appliance extender/distributed power module/power supply and Models EN-PAD, EN-PADR enclosure. Unit comprises of a printed circuit board housed in the EN-PAD or EN-PADR enclosure. The PAD-3 monitors with the polarity of its two input circuits to determine when to operate its four notification circuits. The PAD-3 also provides on trouble relay contact and an auxiliary power circuit. Refer to listee's installation/operation manual for additional detailed product description and operational considerations.

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Unit shall be fully supervised and shall have the 24-hr battery back up as required per code.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as notification appliance extender for use with listee's separately listed compatible fire alarm control units.

This unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999. Refer to manufacturer's Installation Manual for details.

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager